



May 13, 2024

File: 21020-50/WW/OP/Moosomin Regional Park

Moosomin and District Regional Park
Box 1044
MOOSOMIN, SK S0G 3N0

Dear Waterworks Owner/Operator:

RE: Rescinding - Precautionary Drinking Water Advisory – Moosomin Regional Park

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **“Precautionary Drinking Water Advisory”**(PDWA) issued by the Water Security Agency for the Regional Park’s potable water system be rescinded as of Monday May 13, 2024.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The pressure in the distribution system is back to normal operating pressure;
- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Moosomin Regional Park in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 728-7091.

Sincerely,

A handwritten signature in blue ink, appearing to read "Derrick Hoehn".

Derrick Hoehn, A.Sc.T
Supervisor, Environment Officer
Water Security Agency

cc: Roger Miller, South Manager, WSA
Saskatchewan Health Authority - Weyburn